



April 7, 2010

Mr. Toby Steinbeck
Nurazzo, LLC
212 Boring Drive
Dalton, GA 30721

Dear Mr. Steinbeck:

Thank you for choosing Air Quality Sciences, Inc. (AQS), an ISO 9001 registered and ISO 17025 accredited testing laboratory, for your analytical needs. Nurazzo, LLC's "Nurazzo Terrazzo Tile" product was tested by our laboratory for low emitting materials.

Testing was conducted in small environmental chambers following the principles of ASTM D 5116 with the defined product specific test protocols and IAQ emission requirements of California's Section 01350. The test data obtained on these specific products were evaluated relative to the emission requirements in Section 1350 for schools and offices

Calculations were performed using the parameters below to estimate the concentrations of VOCs of concern for use in a classroom environment and/or in an office environment.

Ventilation Rate	Room Volume	Surface Area Product Covers
CLASSROOM		
0.90 air changes per hour (ach)	12.19 m x 7.32 m x 2.59 m = 231.1 m ³ (40 x 24 x 8.5 ft = 8,160 ft ³)	89.2 m ²
OFFICE		
0.75 air changes per hour (ach)	3.05 m x 3.66 m x 2.74 m = 30.6 m ³ (10 x 12 x 9.0 ft = 1,080 ft ³)	11.1 m ²

The product mentioned above as received and tested meets the Section 1350 requirements for use in a classroom and/or in an office with the above parameters.

If you have any questions or concerns about the test results, please contact your Account Manager, Raneé Valles at (678) 444-4058.

Sincerely,

Allyson M. McFry
Chemistry Laboratory Director

Enclosure: AQS Report: 16610-01

2211 Newmarket Parkway
Atlanta, GA 30067
770-933-0638 • Fax 770-933-0641

An ISO 9001 Registered, ISO 17025 Accredited IAQ Firm